

**SLSD LEAD IN WATER LAB RESULTS
MARCH 1, 2024**



M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
U.S. EPA/PA DEP #06-00003

Certificate of Analysis

Laboratory No.: 2409819

Report: 03/06/24

Lab Contact: Jade S Eversole

Attention: Dr. Barbra Plohocki
Reported To: EnviraHealth Corporation
1937 Station Ave.
Center Valley, PA 18034

Project Info: 10-Day TAT Lead in Drinking Water No Pick-Up

Lab ID: 2409819-01 **Collected By:** Client
Sample Desc: 138-1 SLSD - Middle School 138
Notes: L-04

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	12	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Notes and Definitions

L-04 HNO3 preservative was added to the First Draw Lead container upon receipt at the laboratory to pH <2.



107 Angelica Street • Reading, PA 19611 • www.mjreider.com • (610) 374-5129 • fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.

Additional accreditations by MD (261)



Certificate of Analysis

M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
U.S. EPA/PA DEP #06-00003

Laboratory No.: 2409805

Report: 03/06/24

Lab Contact: Jade S Eversole

Attention: Dr. Barbra Plohocki
Reported To: EnviraHealth Corporation
1937 Station Ave.
Center Valley, PA 18034

Project Info: 10-Day TAT Lead in Drinking Water No Pick-Up

Lab ID: 2409805-01 **Collected By:** Client
Sample Desc: 207-1 SLSD - HS - 207
Notes: L-04

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	87	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409805-02 **Collected By:** Client
Sample Desc: 207-2 SLSD - HS - 207
Notes: L-04

Sampled: 03/02/24 06:12

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	177	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Notes and Definitions

L-04 HNO₃ preservative was added to the First Draw Lead container upon receipt at the laboratory to pH <2.



107 Angelica Street • Reading, PA 19611 • www.mjreider.com • (610) 374-5129 • fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.

Additional accreditations by MD (261)

**M.J. Reider Associates, Inc.**ENVIRONMENTAL TESTING LABORATORY
U.S. EPA/PA DEP #06-00003**Certificate of Analysis****Laboratory No.:** 2409806**Report:** 03/06/24**Lab Contact:** Jade S Eversole**Attention:** Dr. Barbra Plohocki
Reported To: EnviraHealth Corporation
1937 Station Ave.
Center Valley, PA 18034**Project Info:** 10-Day TAT Lead in Drinking Water No Pick-Up**Lab ID:** 2409806-01 **Collected By:** Client
Sample Desc: 3 SLSD - HS - Room 213
Notes: L-04**Received:** 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	8	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-02 **Collected By:** Client
Sample Desc: 4 SLSD - HS - Room 213
Notes: L-04**Sampled:** 03/02/24 06:16 **Received:** 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	14	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-03 **Collected By:** Client
Sample Desc: 5 SLSD - HS - Room 213
Notes: L-04**Sampled:** 03/02/24 06:17 **Received:** 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	20	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-04 **Collected By:** Client
Sample Desc: 6 SLSD - HS - Room 213
Notes: L-04**Sampled:** 03/02/24 06:18 **Received:** 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	7	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

107 Angelica Street • Reading, PA 19611 • www.mjreider.com • (610) 374-5129 • fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)



M.J. Reider Associates, Inc.

Lab ID: 2409806-05 Collected By: Client
Sample Desc: 7 SLSD - HS - Room 213
Notes: L-04

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	23	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-06 Collected By: Client
Sample Desc: 8 SLSD - HS - Room 213
Notes: L-04

Sampled: 03/02/24 06:20 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	156	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-07 Collected By: Client
Sample Desc: 9 SLSD - HS - Room 213
Notes: L-04

Sampled: 03/02/24 06:21 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	34	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-08 Collected By: Client
Sample Desc: 10 SLSD - HS - Room 213
Notes: L-04

Sampled: 03/02/24 06:22 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	13	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-09 Collected By: Client
Sample Desc: 11 SLSD - HS - Room 213
Notes: L-04

Sampled: 03/02/24 06:23 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	9	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB



107 Angelica Street • Reading, PA 19611 • www.mjreider.com • (610) 374-5129 • fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)



M.J. Reider Associates, Inc.

Lab ID: 2409806-10 Collected By: Client
Sample Desc: 12 SLSD - HS - Room 213
Notes: L-04

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	11	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-11 Collected By: Client
Sample Desc: 13 SLSD - HS - Room 213
Notes: L-04

Sampled: 03/02/24 06:26 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	3	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-12 Collected By: Client
Sample Desc: 14 SLSD - HS - Room 213
Notes: L-04

Sampled: 03/02/24 06:28 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	1	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409806-13 Collected By: Client
Sample Desc: 15 SLSD - HS - Room 213
Notes: L-04

Sampled: 03/02/24 06:29 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	16	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Notes and Definitions

L-04 HNO₃ preservative was added to the First Draw Lead container upon receipt at the laboratory to pH <2.





Certificate of Analysis

M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
U.S. EPA/PA DEP #06-00003

Laboratory No.: 2409823

Report: 03/06/24

Lab Contact: Jade S Eversole

Attention: Dr. Barbra Plohocki
Reported To: EnviraHealth Corporation
1937 Station Ave.
Center Valley, PA 18034

Project Info: 10-Day TAT Lead in Drinking Water No Pick-Up

Lab ID: 2409823-01 **Collected By:** Client
Sample Desc: B SLSD - Room 145
Notes: L-04

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	19	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-02 **Collected By:** Client
Sample Desc: C SLSD - Room 145
Notes: L-04

Sampled: 03/02/24 06:33

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	9	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-03 **Collected By:** Client
Sample Desc: D SLSD - Room 145
Notes: L-04

Sampled: 03/02/24 06:32

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	3	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-04 **Collected By:** Client
Sample Desc: E SLSD - Room 145
Notes: L-04

Sampled: 03/02/24 06:35

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	1	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB



107 Angelica Street • Reading, PA 19611 • www.mjreider.com • (610) 374-5129 • fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)



M.J. Reider Associates, Inc.

Lab ID: 2409823-05 Collected By: Client
Sample Desc: F SLSD - Room 145
Notes: L-04

Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	3	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-06 Collected By: Client
Sample Desc: G SLSD - Room 145
Notes: L-04

Sampled: 03/02/24 06:37 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	2	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-07 Collected By: Client
Sample Desc: H SLSD - Room 145
Notes: L-04

Sampled: 03/02/24 06:39 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	3	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-08 Collected By: Client
Sample Desc: i SLSD - Room 145
Notes: L-04

Sampled: 03/02/24 06:40 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	29	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-09 Collected By: Client
Sample Desc: J SLSD - Room 145
Notes: L-04

Sampled: 03/02/24 06:41 Received: 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	118	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB





M.J. Reider Associates, Inc.

Lab ID: 2409823-10 Collected By: Client

Sample Desc: K SLSD - Room 145

Notes: L-04

Received: 03/04/24 09:39

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	2	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-11 Collected By: Client

Sample Desc: L SLSD - Room 145

Notes: L-04

Sampled: 03/02/24 06:43

Received: 03/04/24 09:39

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	21	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-12 Collected By: Client

Sample Desc: M SLSD - Room 145

Notes: L-04

Sampled: 03/02/24 06:44

Received: 03/04/24 09:39

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	2	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-13 Collected By: Client

Sample Desc: N SLSD - Room 145

Notes: L-04

Sampled: 03/02/24 06:45

Received: 03/04/24 09:39

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	3	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409823-14 Collected By: Client

Sample Desc: O SLSD - Room 145

Notes: L-04

Sampled: 03/02/24 06:46

Received: 03/04/24 09:39

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<1	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB





M.J. Reider Associates, Inc.

Lab ID: 2409823-15 Collected By: Client

Sample Desc: P SLSD - Room 145

Notes: L-04

Received: 03/04/24 09:39

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	5	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Notes and Definitions

L-04 HNO₃ preservative was added to the First Draw Lead container upon receipt at the laboratory to pH <2.



107 Angelica Street • Reading, PA 19611 • www.mjreider.com • (610) 374-5129 • fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.

Additional accreditations by MD (261)

**M.J. Reider Associates, Inc.**ENVIRONMENTAL TESTING LABORATORY
U.S. EPA/PA DEP #06-00003**Certificate of Analysis****Laboratory No.:** 2409822**Report:** 03/06/24**Lab Contact:** Jade S Eversole**Attention:** Dr. Barbra Plohocki
Reported To: EnviraHealth Corporation
1937 Station Ave.
Center Valley, PA 18034**Project Info:** 10-Day TAT Lead in Drinking Water No Pick-Up**Lab ID:** 2409822-01 **Collected By:** Client
Sample Desc: 261-1 SLSD - IS - Room 261
Notes: L-04**Received:** 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	3	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409822-02 **Collected By:** Client
Sample Desc: 261-2 SLSD - IS - Room 261
Notes: L-04**Sampled:** 03/02/24 07:07 **Received:** 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	1	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409822-03 **Collected By:** Client
Sample Desc: 261-3 SLSD - IS - Room 261
Notes: L-04**Sampled:** 03/02/24 07:10 **Received:** 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<1	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

Lab ID: 2409822-04 **Collected By:** Client
Sample Desc: 261-4 SLSD - IS - Room 261
Notes: L-04**Sampled:** 03/02/24 07:05 **Received:** 03/04/24 09:39
Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	2	ug/l	1	EPA 200.8 Rev 5.4	03/05/24		MPB

107 Angelica Street • Reading, PA 19611 • www.mjreider.com • (610) 374-5129 • fax (610) 374-7234This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)